



# 中国国家强制性产品认证证书

证书编号：2014010907718494

委托人名称、地址

3Y 电力科技公司  
美国加利福尼亚州尔湾镇苯生街 80 号

生产者（制造商）名称、地址

3Y 电力科技公司  
美国加利福尼亚州尔湾镇苯生街 80 号

生产企业名称、地址

深圳辉力电子有限公司  
广东省深圳市宝安区新安街道 73 区 C4、C6、C7、C8、C9、C10、C11 厂房（在  
宝安区 74 区怡园路 5185 号厂房 A3 设有经营场所从事经营活动。）

产品名称和系列、规格、型号

电源供应器  
YH-5102J;YH-5102M 输入:-36 — -72VDC, 38A; 输出详见附件（仅适用于海拔 5000  
米及以下）

产品标准和技术要求

GB17625.1-2012;GB4943.1-2011;GB/T9254-2008 (A 级)

上述产品符合强制性产品认证实施规则 CNCA-01C-020:2010 的要求，  
特发此证。

发证日期：2019 年 07 月 04 日 有效期至：2024 年 07 月 04 日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书为变更证书，证书首次颁发日期：2014 年 08 月 28 日

本证书的相关信息可通过国家认监委网站 [www.cnca.gov.cn](http://www.cnca.gov.cn) 查询



主任：

陆楠



## 中国质量认证中心



# CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

**CERTIFICATE NO.: 2014010907718494**

## **NAME AND ADDRESS OF THE APPLICANT**

3Y Power Technology Inc.  
80 Bunsen Irvine, CA 92618-4210, USA

## **NAME AND ADDRESS OF THE MANUFACTURER**

3Y Power Technology Inc.  
80 Bunsen Irvine, CA 92618-4210, USA

## **NAME AND ADDRESS OF THE FACTORY**

Shenzhen Huili Elec. Co., Ltd.  
Block C, Building 4、6、7、8、9、10、11, County 73, Xin'an, Bao'an, Shenzhen, Guangdong,  
China (Block A, Building 3, No. 5185, YeeYuan Rd., County 74, Bao'an)

## **PRODUCT NAME, MODEL AND SPECIFICATION**

Power Supply  
YH-5102J;YH-5102M Input:-36 — -72VDC , 38A; Output see appendix (Altitude up to  
5000m)

## **THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS**

GB17625.1-2012;GB4943.1-2011;GB/T9254-2008 (Class A)

This is to certify that the above mentioned product(s) complies with the requirements of  
implementation rules for compulsory certification(REFNO.CNCA-01C-020:2010).

**Valid from:** Jul.04,2019

**Valid until:** Jul.04,2024

The validity of the certificate is subject to positive result of the regular follow up  
inspection by issuing certification body until the expiry date.

Date of original issued: Aug.28,2014

The certificate information is available through CNCA's website: [www.cnca.gov.cn](http://www.cnca.gov.cn)



President:

Lu Mei



## **CHINA QUALITY CERTIFICATION CENTRE**



# 中国国家强制性产品认证证书

附 录

第 1 页 共 1 页

证书编号：2014010907718494

纸 号：2313804

型号规格：输入：-36 — -72V , 38A 输出如下：

型号	+5V	+3.3V	+12V	-12V	+5Vsb	+5V 和 +3.3V 合 并最大	最大总功 率
YH-5102J	30A	24A	79A	0.5A	6A	170W	1000W
YH-5102M	45A	24A	79A	0.5A	6A	280W	1000W

注：此附录与证书同时使用时有效。



主 任：





## 中国质量认证中心